



Fairfield-Suisun Unified School District

2490 Hilborn Road • Fairfield, California 94534 • Telephone (707) 399-5148

FAX: (707) 399-5162 • www.fsusd.org

"Fairfield-Suisun Unified School District is a premier learning community that empowers each student to thrive in an ever-changing world."

ADDENDUM NO. 1:

Dated: March 30, 2020

PROJECT: Fairfield High School Pool Upgrades
BID #20F-137

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and previous Addenda as noted below. Acknowledge receipt of this Addendum in the space provided in the Proposal Form. Failure to do so may subject Bidder to disqualification.

A. CLARIFICATIONS

ITEM 1: NONE

B. CHANGES TO SPECIFICATIONS

ITEM 1: REVISE 00 45 10-3 "Classification of Contractors License" to read as follows:

Classification of Contractor's License: Contractor hereby acknowledges that it currently holds valid Type C53 Swimming Pool Contractor's license(s) issued by the State of California, Contractor's State Licensing Board, in accordance with division 3, chapter 9, of the Business and Professions Code and in the classification called for in the Contract Documents.

D. RESPONSE TO BIDDER QUESTIONS

QUESTION 1: Are stainless steel gutter caps to be installed at the rope anchor locations?

ANSWER 1: Yes, provide stainless steel gutter caps at each rope anchor location, forty (40) total.

QUESTION 2: Is the pool to be Re Certified by a Licensed surveyor, after new tile has been installed?

ANSWER 2: Yes, see attached requirements.

QUESTION 3: If a contractor is not using any subcontractors does 00 45 55 DVBE still apply?

ANSWER 3: DVBE is not required if subcontractors are not used

QUESTION 4: Document 00 45 10-3 States the License C-12 is required. I think this is an error. Can you confirm.

ANSWER 4: Yes it was a clerical error, the required license is C53 Swimming Pool Contractor

QUESTION 5: We discussed placing "tile surrounds" around the floor inlet fittings. We recommend Including these in the scope of work.

End of Addendum No.1

ANSER 5: ADG Response: Floor inlet tile surrounds are not required.

QUESTION6: There was a question raised during the pre-bid walk regarding the need for re-sealing the gutters. Does the job include re-sealing the gutter or surge tank?

ANSWER 6: Yes, pool gutters are to be cleaned and waterproofed per 1/SP-2 and specifications section 13 11 05 2.04 and 3.02. The surge chamber does not receive new waterproofing.

QUESTION 7: Does the District have information regarding the “water table” level in the Fairfield HS area?

ANSWER 7: See demolition/construction note #1 on DP-1. Caution shall be exercised during pool drain down.

QUESTION 8: Will there be power available for our crews at the job site?

ANSWER 8: Yes, power will be available on site

QUESTION 9: The coverage the documents requested; For Commercial General liability. \$4,000,000 general aggregate. (Umbrella) We carry \$2,000,000 Excess Liability \$6,000,000, We carry \$4,000,000 And we do not carry Builders Risk. Is the district steadfast on these coverages for this project?

ANSWER 9: Refer to document 00 71 00-4 Special Conditions Insurance policy limits in the project manual

ATTACHEMNTS:

Certification Requirements (1) page

CERTIFICATION REQUIREMENTS

* THE CONTRACTOR SHALL RETAIN AN INDEPENDENT LICENSED SURVEYOR TO PROVIDE PROOF OF COMPLIANCE FOR REQUIRED POOL LENGTHS AS FOLLOWS: (RECOMMEND PATRELL ENG. GROUP (626) 335-4362)

SHORT COURSE-25YDS: (ALLOWS FOR TOUCH PADS AT ONE END) 75'-0 5/16" MIN.: 75'-1 3/16" MAX.

SHORT COURSE-25M: (ALLOWS FOR TOUCH PADS AT ONE END) 82'-0 9/16" MIN.: 82'-1 7/16" MAX.

TOLERANCE AGAINST LENGTH SHALL EXTEND IN A VERTICAL PLANE 0.3M (12") ABOVE AND 0.8M. (2'-7 1/2") BELOW THE SURFACE OF THE WATER AT ALL POINTS OF BOTH END WALLS TYP. OF ALL COURSES.

THE INDEPENDENT LICENSED SURVEYOR SHALL FILL OUT, NOTARIZE AND FILE OFFICIAL CERTIFICATION FORM(S) WITH USA SWIMMING.

** CONTRACTOR SHALL RETAIN A LICENSED ENGINEER TO CERTIFY THE FIELD BUILT MAIN DRAIN SYSTEMS AS V.G.B. COMPLIANT.